Catalog Number:	8848-GSC1
Item Description:	N1 SCREW CVR GUTTER
UPC Code:	784572109490

Brand Name:	Milbank
Type:	Lay In Wireway
Application:	Wireway
Standard:	UL Listed, Type 1
Cover Type:	Screw Cover
Enclosure:	Indoor Enclsoure
Nominal Cross Section:	8x8
Straight Section Length:	48
Material:	Steel with Powder Coat Finish
Finish:	ANSI 61 Gray
Knockouts:	True



Additional Specifications:	UL Listed:UL Listed
	NEMA Rating:Type 1

Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

CATALOG#	LABEL#
8848-GSC1-( )	1002943
RC-8848-GSC1-( )	1125051
SPS-884( )	1132575

NO.	QTY.	PART NO.	DESCRIPTION
1	1	(SEE CHART)	BACK
2	1	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	LABEL (U/L LISTING)
4	1	1002913	LABEL, RATING
5	4	1001290	SCREW, 10-32 X 5/16
6	3	1002880	BAG ASSY.



SUFFIX	BACK #	COVER #
-SU	1001331	1002315
-SUC	1129035	1129028
-SO	1129036	1011830
-SUNK	1001329	1002315
-NK	1010698	1011830
-SUNKC	1129037	1129028





SUFFIX	FINISH
NONE	PAINTED
-NP	NOT PAINTED

NOTE:
1. PLACE BAG ASS'Y INSIDE ENCLOSURE. (NOT SHOWN)

D	8-29-07	ADDED BACK & COVER CHART ECO. 15946	DL			
D1	5/7/08	ADDED CHART & REMOVED NOTE #2 (ECO.17139)	JLT			

Material:	14 GA. - SEE CHART	MILBANK MANUFACTURING CO.	General Offices: Kansas City, MO
Finish:	SEE CHART	Title:	SCREW COVER WIREWAY 8 x 8 x 48, TYPE 1 NEMA ENCLOSURE
Tolerances: Unless Specified Otherwise: X.X ±.1, X.XX ±.03, X.XXX ±.015, X° ±2°	Third Angle Projection	Catalog No.:	(SEE CHART)
		Customer:	MILBANK STANDARD
Scale: NTS	Checked By:	Drawing No.:	257-11
Drawn By: DY	Approved By:	Date: 08/19/02	Sheet 1 of 1